



Bureau of Fire Prevention
Harrison Township Fire District #1
 312 Ewan Rd
 Mullica Hill NJ, 08062
 Office: 856-478-0423
 Email: mark@htfd23.com



Certificate of Smoke Alarm, Carbon Monoxide Alarm
Portable Fire Extinguisher Compliance
Pre-Check List

As required by N.J.A.C. 5:70 – 2.3

Smoke Alarm Requirements

Built prior to 1977

One battery-operated smoke alarm is required on each level including the basement _____

Built from July 1, 1977 thru August 5, 1984

Electric smoke alarms system required on the sleeping level and in the basement
 On levels without the electric smoke alarm system, a battery operated smoke alarm shall be installed _____

Built from August 6, 1984 thru September 3, 1991

Interconnected electric smoke alarms shall be located on each level of the dwelling
 with on in the vicinity of the bedrooms _____

Built from September 4, 1991 to present

Interconnected electric smoke alarms with battery backup should be located on every level of the dwelling
 including the basement, sleeping areas and in every bedroom. The original smoke alarm system shall be
 maintained. _____

Notes:

All single station battery operated smoke alarms must be “10 year sealed battery powered” type
 Battery powered smoke alarms do not replace the electric smoke alarms when required _____

All Smoke alarms shall not be older than 10 years from the date of manufacture _____

Carbon Monoxide Alarm Requirements

A Carbon monoxide alarm shall be located within 10 feet of every bedroom _____

The carbon monoxide alarms shall not be older than the manufacturers recommended replacement date _____

Portable Fire Extinguisher Requirements

The extinguisher must be a minimum of **2A-10:BC** rated extinguisher and not larger than 10 lbs _____

The extinguisher must be mounted with the manufacturers hanging bracket so the instructions are clearly visible _____

The extinguisher must be mounted within 10 feet of the kitchen and located in the exit path of the kitchen _____

The top of the extinguisher shall not be more than five feet above the floor _____

The extinguisher shall be readily accessible and not obstructed from view – cannot be located behind closed doors or cabinets _____

Note: The extinguisher shall be new within the past 12 months with receipt (**OR**) the seller shall have the extinguisher serviced by a certified
 Division of Fire Safety extinguisher contractor.